

# CERTIFICATE

## HYGIENIC QUALIFICATION OF AIR PURIFICATION DEVICE ‚PAC 1200‘ BASED ON VDI 6022-1:2018-01

CONTRACTEE	Miele & Cie. KG
INSPECTED OBJECT	Air purification device model PAC 1200
INSPECTED SCOPE	Evaluation of the hygienic safety and usability in medically used rooms without particular hygienic requirements (e.g. room class II) and conformity based on VDI 6022-1: 2018-01.
INSPECTION REPORT	11292-LR-GUT-1200-0421-A
INSPECTION RESULT	The hygienic harmlessness and conformity of the air purification device PAC 1200 (with a HEPA filter of class H-14 according to DIN EN 1822-1:2019-10) based on VDI 6022-1:2018-01 is confirmed. A particulate and microbiological reduction in the room air has been demonstrated through the use of the air cleaning device.
DATE OF ISSUE	20.04.2021
AUTHORISATION	Dr. Frank Wille, Münster

Dr. Frank Wille